



®

TM

Ref. Certif. No.

HU-004017

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Surge Protective Device for PV application
Name and address of the applicant	ProJoy Electric Co., Ltd. XinTang Industrial Zone, North-city Street, PingJiang District, Suzhou, 215000 Jiangsu, P.R. China
Name and address of the manufacturer	ProJoy Electric Co., Ltd. XinTang Industrial Zone, North-city Street, PingJiang District, Suzhou, 215000 Jiangsu, P.R. China
Name and address of the factory	ProJoy Electric Co., Ltd. XinTang Industrial Zone, North-city Street, PingJiang District, Suzhou, 215000 Jiangsu, P.R. China
Ratings and principal characteristics	Ucpv: 600 V DC; In: 20 kA; Imax: 40 kA; Iscpv: 50 A Up: 3.0 kV(+/- to PE); indoor, Itotal: 40 kA(8/20 µs); IP20; one port; Class II
Trademark (if any)	PROJOY
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	PESP-600
Additional information (if necessary may also be reported on page 2)	Detailed information refer to test report CN22CTYR 001
A sample of the product was tested and found to be in conformity with	IEC 61643-31:2018
As shown in the Test Report Ref. No. which forms part of this Certificate	CN22CTYR 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2022-08-01

Signature:

Wencai Zhang