

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50552900

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
W.Y.

Unser Zeichen *Our Reference*
01-ZWC-CN222ONN 001

Ausstellungsdatum *Date of Issue*
02.08.2022 (day/mo/yr)

Genehmigungsinhaber *License Holder*
ProJoy Electric Co., Ltd.
XinTang Industrial Zone,
North-city Street,
PingJiang District
Suzhou
215000 Jiangsu
P.R. China

Fertigungsstätte *Manufacturing Plant*
ProJoy Electric Co., Ltd.
XinTang Industrial Zone,
North-city Street,
PingJiang District
Suzhou
215000 Jiangsu
P.R. China

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111257320

Geprüft nach *Tested acc. to*
EN 61643-31:2019
IEC 61643-31:2018

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

Surge Protector (Surge Protective Device for PV application)

Type Designation: PESP-600
Trade Mark : PROJOY
Ucpv : 600 V DC
In : 20 kA
Imax : 40 kA
Itotal : 40 kA
Up : 3 kV(+ to PE, - to PE)
Type of SPD : Type 2
Number of ports : One port
Iscpv : 50 A
IP code : IP20

6

6

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.



Zertifizierungsstelle

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

Yongming Yang

ProJoy Electric Co., Ltd.
Mr. Walter Yang

Date : 02.08.2022
Our ref. : ZWC 01
Your ref.: W.Y.

XinTang Industrial Zone,
North-city Street,
PingJiang District
Suzhou
215000 Jiangsu
P.R. China

Ref : R TÜV-Mark Approval

Type of Equipment : SPD
Model Designation : See Certificate
Certificate No. : R 50552900 0001
Report No. : CN2220NN 001

Dear Mr. Walter Yang,

The above specified technical equipment has been tested and found to be in accordance with the relevant requirements.

Enclosed you will find the certificate of approval.

If cancellation of the certificate is submitted by November 15 in a given year, no fee will be charged for the following year.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

Please contact our office for approval of your new products.

With kind regards,

Certification Body

Yongming Yang

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询